

**WATER AUTHORITY OF GREAT NECK NORTH**  
**2013 SOURCE TESTING RESULTS**

Supplement to the 2013 Annual Drinking Water Quality Report as required by part #5 of the new York State Sanitary Code

<b>PHYSICAL (PHY.1)</b>	<b>MCL (UNITS)</b>	<b>WELL #2A</b>	<b>WELL #5</b>	<b>WELL #6</b>	<b>WELL #7</b>	<b>WELL #8</b>
Turbidity	5.0	N.D.	1.8	N.D.	1	N.D.
Color	15.0	N.D.	5	N.D.	5	N.D.
Odor	3.0	0	0	0	0	0
Temperature	Deg. C.	15.0	14.0	14.0	15.0	15.0
<b>INORGANIC (IOC. 1,2,3)</b>	<b>MCL (mg/L)</b>	<b>WELL #2A (mg/L)</b>	<b>WELL #5 (mg/L)</b>	<b>WELL #6 (mg/L)</b>	<b>WELL #7 (mg/L)</b>	<b>WELL #8 (mg/L)</b>
Antimony	0.006	N.D.	N.D.	N.D.	N.D.	N.D.
Arsenic	0.01	N.D.	N.D.	N.D.	N.D.	N.D.
Barium	2.0	0.027	0.066	0.047	0.012	0.051
Beryllium	0.004	N.D.	N.D.	N.D.	N.D.	N.D.
Cadmium	0.005	N.D.	N.D.	N.D.	N.D.	N.D.
Chromium	0.10	N.D.	N.D.	N.D.	N.D.	N.D.
Free Cyanide	0.20	N.D.	N.D.	N.D.	N.D.	N.D.
Fluoride	2.20	0.15	0.22	N.D.	0.11	0.11
Lead	0.015	N.D.	N.D.	N.D.	N.D.	N.D.
Mercury	2.0	N.D.	N.D.	N.D.	N.D.	N.D.
Nickel	0.10	0.0007	N.D.	0.001	N.D.	N.D.
Selenium	0.05	N.D.	N.D.	0.006	N.D.	N.D.
Silver	0.10	N.D.	N.D.	N.D.	N.D.	N.D.
Thallium	0.002	N.D.	N.D.	N.D.	N.D.	N.D.
Ammonia	N/A	N.D.	N.D.	N.D.	N.D.	N.D.
Copper	1.30	N.D.	N.D.	N.D.	N.D.	N.D.
MBAS	N/A	N.D.	N.D.	N.D.	N.D.	N.D.
Chloride	250	49.3	141.0	38.0	21.7	55.9
Calcium	N/A	23.5	38.0	29.0	25.8	33.3
Iron	0.3	N.D.	0.030	N.D.	0.100	N.D.
Magnesium	N/A	11.5	17.6	13.9	12.0	18.2
Manganese	0.3	N.D.	0.08	0.210	0.050	N.D.
Nitrates	10.0	3.05	0.72	1.2	0.1	3.4
Nitrites	1.0	N.D.	N.D.	N.D.	N.D.	N.D.
Sodium	N/A	18.4	26.0	14.5	15.2	18.1
Sulfate	250.0	28.3	13.2	43.2	24.5	49.6
Zinc	5.0	N.D.	0.02	N.D.	N.D.	0.020
Perchlorate	See notes	N.D.	N.D.	N.D.	N.D.	N.D.
<b>CORROSIVITY (COR.1)</b>						
Calcium Hardness		58.8	94.9	72.4	64.4	83.3
Langelier Index		-1.8	-1.6	-1.8	-2.1	-1.5
PH		6.6	6.7	6.4	6.1	6.8
Total Alkalinity		49.1	45.8	63.0	74.0	53.5
Disssolved Solids		219.0	366.0	179.0	152.0	266.0
Total Hardness		106.0	168.0	129.0	114.0	158.0

**NOTES:**

**Sodium:**

The New York State Department of Health recommends that Sodium not exceed 20 mg/L for severely restricted sodium diets and 270 mg/L for moderately restricted sodium diets.

**Perchlorate:**

The Primary Action Level is 18 ppb. If a well exceeds the Primary Action Level, the supplier must perform public notification and the well must be taken out of service or appropriate steps (such as blending) must be taken to assure the safety of the public's health.

The Secondary Action Level is 5 ppb. If a well exceeds the Secondary Action Level, State notification is required and the well must be monitored quarterly and operated to reduce the discharge of perchlorate into the distribution system.

N.D. = NON-DETECT

**WATER AUTHORITY OF GREAT NECK NORTH  
2013 SOURCE TESTING RESULTS**

Supplement to the 2013 Annual Drinking Water Quality Report as required by part #5 of the new York State Sanitary Code

<b>PHYSICAL (PHY.1)</b>	<b>MCL (UNITS)</b>	<b>WELL #9</b>	<b>WELL #10A</b>	<b>WELL #11</b>	<b>WELL #12</b>	<b>WELL #13</b>
Turbidity	5.0	N.D.	N.D.	1.1	N.D.	N.D.
Color	15.0	N.D.	N.D.	N.D.	N.D.	N.D.
Odor	3.0	0	0	0	0	0
Temperature	Deg. C.	15.0	14.0	15.0	14.0	15.0
<b>INORGANIC (IOC. 1,2,3)</b>	<b>MCL (mg/L)</b>	<b>WELL #9 (mg/L)</b>	<b>WELL #10A (mg/L)</b>	<b>WELL #11 (mg/L)</b>	<b>WELL #12 (mg/L)</b>	<b>WELL #13 (mg/L)</b>
Antimony	0.006	N.D.	N.D.	N.D.	N.D.	N.D.
Arsenic	0.05	N.D.	N.D.	N.D.	N.D.	N.D.
Barium	2.0	0.035	0.020	0.020	0.0106	0.0083
Beryllium	0.004	N.D.	N.D.	N.D.	N.D.	N.D.
Cadmium	0.005	N.D.	N.D.	N.D.	N.D.	N.D.
Chromium	0.10	N.D.	N.D.	N.D.	N.D.	N.D.
Free Cyanide	0.20	N.D.	N.D.	N.D.	N.D.	N.D.
Fluoride	2.20	N.D.	0.11	N.D.	N.D.	0.1
Lead	0.015	N.D.	N.D.	N.D.	N.D.	N.D.
Mercury	2.0	N.D.	N.D.	N.D.	N.D.	N.D.
Nickel	0.10	N.D.	N.D.	0.0006	N.D.	N.D.
Selenium	0.05	N.D.	N.D.	N.D.	N.D.	N.D.
Silver	0.10	N.D.	N.D.	N.D.	N.D.	N.D.
Thallium	0.002	N.D.	N.D.	N.D.	N.D.	N.D.
Ammonia	N/A	N.D.	N.D.	N.D.	N.D.	N.D.
Copper	1.3	N.D.	N.D.	N.D.	N.D.	N.D.
MBAS	N/A	N.D.	N.D.	N.D.	N.D.	N.D.
Chloride	250	71.4	21.6	9.7	31.9	57.3
Calcium	N/A	30	20.7	16.9	20.7	23.4
Iron	0.3	N.D.	N.D.	0.09	0.03	0.05
Magnesium	N/A	13.8	10.6	8.0	11.4	13.9
Manganese	0.3	N.D.	N.D.	N.D.	N.D.	N.D.
Nitrates	10.0	2.52	0.24	2.34	2.28	2.55
Nitrites	1.0	N.D.	N.D.	N.D.	N.D.	N.D.
Sodium	N/A	33.1	13.6	6.2	9.9	13.3
Sulfate	250.0	37.7	24.1	14.5	21.7	17.1
Zinc	5.0	0.02	0.06	N.D.	N.D.	N.D.
Perchlorate	See notes	N.D.	N.D.	N.D.	1.9	1.3
<b>CORROSIVITY (COR.1)</b>						
Calcium Hardness		75.0	51.6	42.1	51.6	58.3
Langelier Index		-1.6	-2.3	-1.6	-1.9	-1.6
PH		6.6	6.2	7.0	6.6	6.8
Total Alkalinity		62.4	49.1	43.6	45.6	49.4
Disssolved Solids		265.0	137.0	130.0	173.0	235.0
Total Hardness		132.0	95.4	75.1	98.5	116.0

**NOTES:**

**Sodium:**

The New York State Department of Health recommends that Sodium not exceed 20 mg/L for severely restricted sodium diets and 270 mg/L for moderately restricted sodium diets.

**Perchlorate:**

The Primary Action Level is 18 ppb. If a well exceeds the Primary Action Level, the supplier must perform public notification and the well must be taken out of service or appropriate steps (such as blending) must be taken to assure the safety of the public's health.

The Secondary Action Level is 5 ppb. If a well exceeds the Secondary Action Level, State notification is required and the well must be monitored quarterly and operated to reduce the discharge of perchlorate into the distribution system.

N.D. = NON-DETECT

**WATER AUTHORITY OF GREAT NECK NORTH  
2013 SOURCE TESTING RESULTS**

Supplement to the 2013 Annual Drinking Water Quality Report as required by part #5 of the new York State Sanitary Code

<b>PESTICIDES AND HERBICIDES (SOC. 1,2)</b>	<b>MCL (ug/L)</b>	<b>WELL #2A (ug/L)</b>	<b>WELL #5 (ug/L)</b>	<b>WELL #6 (ug/L)</b>	<b>WELL #7 (ug/L)</b>	<b>WELL #8 (ug/L)</b>
Alachlor	2.0	N.D.	N.D.	N.D.	N.D.	N.D.
Aldicarb	3.0	N.D.	N.D.	N.D.	N.D.	N.D.
Aldicarb Sulfoxide	4.0	N.D.	N.D.	N.D.	N.D.	N.D.
Aldicarb Sulfone	2.0	N.D.	N.D.	N.D.	N.D.	N.D.
Atrazine	3.0	N.D.	N.D.	N.D.	N.D.	N.D.
Carbofuran	40.0	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorodane	2.0	N.D.	N.D.	N.D.	N.D.	N.D.
DBCP or 1,2-Dibromo-3-chloropropane	0.2	N.D.	N.D.	N.D.	N.D.	N.D.
2,4-D	50.0	N.D.	N.D.	N.D.	N.D.	N.D.
Endrin	2.0	N.D.	N.D.	N.D.	N.D.	N.D.
1,2- Dibromoethane	0.05	N.D.	N.D.	N.D.	N.D.	N.D.
Heptachlor	0.4	N.D.	N.D.	N.D.	N.D.	N.D.
Heptachlor Expoxide	0.2	N.D.	N.D.	N.D.	N.D.	N.D.
Lindane	0.2	N.D.	N.D.	N.D.	N.D.	N.D.
Methoxychlor	50.0	N.D.	N.D.	N.D.	N.D.	N.D.
Pentachlorophenol	1.0	N.D.	N.D.	N.D.	N.D.	N.D.
Toxaphene	3.0	N.D.	N.D.	N.D.	N.D.	N.D.
2,4,5-TP (Silvex)	10.0	N.D.	N.D.	N.D.	N.D.	N.D.
Aldrin	5.0	N.D.	N.D.	N.D.	N.D.	N.D.
Benzo (a) pyrene	0.2	N.D.	N.D.	N.D.	N.D.	N.D.
Butachlor	50.0	N.D.	N.D.	N.D.	N.D.	N.D.
Carbaryl	50.0	N.D.	N.D.	N.D.	N.D.	N.D.
Dalapon	50.0	N.D.	N.D.	N.D.	N.D.	N.D.
Bis-(2-ethylhexyl) adipate	50.0	N.D.	N.D.	N.D.	N.D.	N.D.
Bis-(2-ethylhexyl) phthalates	6.0	N.D.	N.D.	N.D.	N.D.	N.D.
Dicamba	50.0	N.D.	N.D.	N.D.	N.D.	N.D.
Dieldrin	5.0	N.D.	N.D.	N.D.	N.D.	N.D.
Dinoseb	7.0	N.D.	N.D.	N.D.	N.D.	N.D.
Glyphosate	50.0	N.D.	N.D.	N.D.	N.D.	N.D.
Hexachlorobenzene	1.0	N.D.	N.D.	N.D.	N.D.	N.D.
Hexachlorocyclopentadiene	50.0	N.D.	N.D.	N.D.	N.D.	N.D.
3-Hydroxycarbofuran	50.0	N.D.	N.D.	N.D.	N.D.	N.D.
Methomyl	50.0	N.D.	N.D.	N.D.	N.D.	N.D.
Metolachlor	50.0	N.D.	N.D.	N.D.	N.D.	N.D.
Metribuzin	50.0	N.D.	N.D.	N.D.	N.D.	N.D.
Oxamyl	50.0	N.D.	N.D.	N.D.	N.D.	N.D.
Pichloram	50.0	N.D.	N.D.	N.D.	N.D.	N.D.
Propachlor	50.0	N.D.	N.D.	N.D.	N.D.	N.D.
Simazine	4.0	N.D.	N.D.	N.D.	N.D.	N.D.
Total PCB's	0.5	N.D.	N.D.	N.D.	N.D.	N.D.
Endothol	50.0	N.D.	N.D.	N.D.	N.D.	N.D.
Diquat	20.0	N.D.	N.D.	N.D.	N.D.	N.D.
Dioxin	0.00000003	N.D.	N.D.	N.D.	N.D.	N.D.

**NOTE:**

N.D. = NON-DETECT

**WATER AUTHORITY OF GREAT NECK NORTH  
2013 SOURCE TESTING RESULTS**

Supplement to the 2013 Annual Drinking Water Quality Report as required by part #5 of the new York State Sanitary Code

<b>PESTICIDES AND HERBICIDES (SOC. 1,2)</b>	<b>MCL (ug/L)</b>	<b>WELL #9 (ug/L)</b>	<b>WELL #10A (ug/L)</b>	<b>WELL #11 (ug/L)</b>	<b>WELL #12 (ug/L)</b>	<b>WELL #13 (ug/L)</b>	<b>WELL #14 (ug/L)</b>
Alachlor	2.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Aldicarb	3.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Aldicarb Sulfoxide	4.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Aldicarb Sulfone	2.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Atrazine	3.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Carbofuran	40.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorodane	2.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
DBCP or 1,2-Dibromo-3-chloropropane	0.2	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
2,4-D	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Endrin	2.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2- Dibromoethane	0.05	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Heptachlor	0.4	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Heptachlor Expoxide	0.2	0.021	N.D.	N.D.	N.D.	N.D.	N.D.
Lindane	0.2	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Methoxychlor	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Pentachlorophenol	1.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Toxaphene	3.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
2,4,5-TP (Silvex)	10.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Aldrin	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Benzo (a) pyrene	0.2	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Butachlor	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Carbaryl	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Dalapon	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bis-(2-ethylhexyl) adipate	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bis-(2-ethylhexyl) phthalates	6.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Dicamba	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Dieldrin	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Dinoseb	7.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Glyphosate	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Hexachlorobenzene	1.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Hexachlorocyclopentadiene	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
3-Hydroxycarbofuran	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Methomyl	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Metolachlor	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Metribuzin	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Oxamyl	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Pichloram	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Propachlor	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Simazine	4.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Total PCB's	0.5	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Endothol	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Diquat	20.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Dioxin	0.00000003	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.

**NOTE:**  
N.D. = NON-DETECT

**WATER AUTHORITY OF GREAT NECK NORTH  
2013 SOURCE TESTING RESULTS**

Supplement to the 2013 Annual Drinking Water Quality Report as required by part #5 of the new York State Sanitary Code

VOLATILE HALOCARBONS (POC's)	MCL (ug/L)	WELL #2A (ug/L)			WELL #9 (ug/L)			TREATED WELLS 2A & 9 (ug/L)		
		HIGH	LOW	AVG	HIGH	LOW	AVG	HIGH	LOW	AVG
Dichlorodifluoromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorodifluoromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chloromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Vinyl Chloride	2.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromomethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Trichloroflouromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1-Dichloroethene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Methylene Chloride	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
trans-1,2-Dichloroethene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1-Dichloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
2,2-Dichloropropane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
cis-1,2-Dichloroethene	5.0	2.2	1.2	1.5	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chloroform	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromochloromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1,1-Trichloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1-Dichloropropene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Carbon Tetrachloride	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2-Dichloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Trichloroethene	5.0	4.0	1.9	2.5	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2-Dichloropropane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromodichloromethane	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	0.8	N.D.	N.D.
Dibromomethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1,2-Trichloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Tetrachloroethene	5.0	6.4	3.8	5.1	1.8	N.D.	N.D.	N.D.	N.D.	N.D.
1,3-Dichloropropane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorodibromomethane	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1,1,2-Tetrachloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromoform	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1,2,2-Tetrachloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2,3-Trichloropropane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
2-Chlorotoluene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
4-Chlorotoluene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,3 -Dichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,4 -Dichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2 -Dichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.

**NOTES:**

The elevated levels of Tetrachloroethene are removed by air stripping at our Water Mill Lane and Weybridge pumping facilities. The volatile organic chemicals are tested quarterly at each well except when a well has not been used during the respective quarter. Volatile organic chemicals will be sampled at least once per year regardless if a well is used or not. Wells #2A, #6, #8, #9, #12, #13 and #14 raw water and treated water are tested for organic chemicals on a monthly basis when in service during the respective month.

N.D. = NON-DETECT

**WATER AUTHORITY OF GREAT NECK NORTH**  
**2013 SOURCE TESTING RESULTS**

Supplement to the 2013 Annual Drinking Water Quality Report as required by part #5 of the new York State Sanitary Code

<b>VOLATILE AROMATICS (POC's- Continued)</b>	<b>MCL (ug/L)</b>	<b>WELL #2A (ug/L)</b>			<b>WELL #9 (ug/L)</b>			<b>TREATED WELLS 2A &amp; 9 (ug/L)</b>		
		HIGH	LOW	AVG	HIGH	LOW	AVG	HIGH	LOW	AVG
1,2,4-Trichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Hexachlorobutadiene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2,3-Trichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Trans-1,3-Dichloropropene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Cis-1,3-Dichloropropene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Benzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Toluene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Ethyl Benzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
m- Xylene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
p- Xylene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
o- Xylene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Styrene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Isopropylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
n-propylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,3,5-Trimethylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
tert-Butylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2,4-Trimethylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
sec-Butylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
p- Isopropyltoluene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
n-Butylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Methyl Tert. Butyl Ether (MTBE)	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorodifluoromethane	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Freon 113	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.

**NOTES:**

The elevated levels of Tetrachloroethene are removed by air stripping at our Water Mill Lane and Weybridge pumping facilities. The volatile organic chemicals are tested quarterly at each well except when a well has not been used during the respective quarter. Volatile organic chemicals will be sampled at least once per year regardless if a well is used or not. Wells #2A, #6, #8, #9, #12, #13 and #14 raw water and treated water are tested for organic chemicals on a monthly basis when in service during the respective month.

N.D. = NON-DETECT

**WATER AUTHORITY OF GREAT NECK NORTH  
2013 SOURCE TESTING RESULTS**

Supplement to the 2013 Annual Drinking Water Quality Report as required by part #5 of the new York State Sanitary Code

VOLATILE HALOCARBONS (POC's)	MCL (ug/L)	WELL #5 (ug/L)			WELL #6 (ug/L)			TREATED WELL #6 (ug/L)			WELL #7 (ug/L)		
		HIGH	LOW	AVG	HIGH	LOW	AVG	HIGH	LOW	AVG	HIGH	LOW	AVG
Dichlorodifluoromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorodifluoromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chloromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Vinyl Chloride	2.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromomethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Trichlorofluoromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1-Dichloroethene	5.0	N.D.	N.D.	N.D.	0.8	N.D.	0.6	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Methylene Chloride	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
trans-1,2-Dichloroethene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1-Dichloroethane	5.0	N.D.	N.D.	N.D.	2.7	1.1	2.2	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
2,2-Dichloropropane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
cis-1,2-Dichloroethene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chloroform	50.0	N.D.	N.D.	N.D.	0.8	N.D.	0.6	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromochloromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1,1-Trichloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1-Dichloropropene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Carbon Tetrachloride	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2-Dichloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Trichloroethene	5.0	N.D.	N.D.	N.D.	1.2	0.8	1.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2-Dichloropropane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromodichloromethane	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Dibromomethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1,2-Trichloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Tetrachloroethene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	0.5	N.D.	N.D.
1,3-Dichloropropane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorodibromomethane	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1,1,2-Tetrachloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromoform	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	0.5	N.D.	N.D.	N.D.	N.D.	N.D.
1,1,2,2-Tetrachloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2,3-Trichloropropane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
2-Chlorotoluene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
4-Chlorotoluene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,3 -Dichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,4 -Dichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2 -Dichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.

**NOTES:**

The elevated levels of Tetrachloroethene are removed by air stripping at our Water Mill Lane and Weybridge pumping facilities. The volatile organic chemicals are tested quarterly at each well except when a well has not been used during the respective quarter. Volatile organic chemicals will be sampled at least once per year regardless if a well is used or not. Wells #2A, #6, #8, #9, #12, #13 and #14 raw water and treated water are tested for organic chemicals on a monthly basis when in service during the respective month.

N.D. = NON-DETECT

**WATER AUTHORITY OF GREAT NECK NORTH  
2013 SOURCE TESTING RESULTS**

Supplement to the 2013 Annual Drinking Water Quality Report as required by part #5 of the new York State Sanitary Code

VOLATILE AROMATICS (POC's-Continued)	MCL (ug/L)	WELL #5 (ug/L)			WELL #6 (ug/L)			TREATED WELL #6 (ug/L)			WELL #7 (ug/L)		
		HIGH	LOW	AVG	HIGH	LOW	AVG	HIGH	LOW	AVG	HIGH	LOW	AVG
1,2,4-Trichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Hexachlorobutadinene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2,3-Trichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Trans-1,3-Dichloropropene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Cis-1,3-Dichloropropene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Benzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Toluene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Ethyl Benzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
m- Xylene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
p- Xylene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
o- Xylene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Styrene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Isopropylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
n-propylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,3,5-Trimethylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
tert-Butylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2,4-Trimethylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
sec-Butylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
p- Isopropyltoluene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
n-Butylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Methyl Tert. Butyl Ether (MTBE)	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorodifluoromethane	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Freon 113	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.

**NOTES:**

The elevated levels of Tetrachloroethene are removed by air stripping at our Water Mill Lane and Weybridge pumping facilities. The volatile organic chemicals are tested quarterly at each well except when a well has not been used during the respective quarter. Volatile organic chemicals will be sampled at least once per year regardless if a well is used or not. Wells #2A, #6, #8, #9, #12, #13 and #14 raw water and treated water are tested for organic chemicals on a monthly basis when in service during the respective month.

N.D. = NON-DETECT



**WATER AUTHORITY OF GREAT NECK NORTH  
2013 SOURCE TESTING RESULTS**

Supplement to the 2013 Annual Drinking Water Quality Report as required by part #5 of the new York State Sanitary Code

<b>VOLATILE HALOCARBONS (POC's)</b>	<b>MCL (ug/L)</b>	<b>WELL #8 (ug/L)</b>			<b>Treated WELL #8 (ug/L)</b>			<b>WELL #10A (ug/L)</b>		
		<b>HIGH</b>	<b>LOW</b>	<b>AVG</b>	<b>HIGH</b>	<b>LOW</b>	<b>AVG</b>	<b>HIGH</b>	<b>LOW</b>	<b>AVG</b>
Dichlorodifluoromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorodifluoromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chloromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Vinyl Chloride	2.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromomethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Trichlorofluoromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1-Dichloroethene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Methylene Chloride	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
trans-1,2-Dichloroethene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1-Dichloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
2,2-Dichloropropane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
cis-1,2-Dichloroethene	5.0	1.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chloroform	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromochloromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1,1-Trichloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1-Dichloropropene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Carbon Tetrachloride	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2-Dichloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Trichloroethene	5.0	0.9	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2-Dichloropropane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromodichloromethane	50.0	N.D.	N.D.	N.D.	0.7	N.D.	N.D.	N.D.	N.D.	N.D.
Dibromomethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1,2-Trichloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Tetrachloroethene	5.0	19.0	12.1	14.5	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,3-Dichloropropane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorodibromomethane	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1,1,2-Tetrachloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromoform	50.0	N.D.	N.D.	N.D.	1.7	N.D.	N.D.	N.D.	N.D.	N.D.
1,1,2,2-Tetrachloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2,3-Trichloropropane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
2-Chlorotoluene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
4-Chlorotoluene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,3 -Dichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,4 -Dichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2 -Dichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.

**NOTES:**

The elevated levels of Tetrachloroethene are removed by air stripping at our Water Mill Lane and Weybridge pumping facilities. The volatile organic chemicals are tested quarterly at each well except when a well has not been used during the respective quarter. Volatile organic chemicals will be sampled at least once per year regardless if a well is used or not. Wells #2A, #6, #8, #9, #12, #13 and #14 raw water and treated water are tested for organic chemicals on a monthly basis when in service during the respective month.

N.D. = NON-DETECT

**WATER AUTHORITY OF GREAT NECK NORTH**  
**2013 SOURCE TESTING RESULTS**

Supplement to the 2013 Annual Drinking Water Quality Report as required by part #5 of the new York State Sanitary Code

VOLATILE AROMATICS (POC's-Continued)	MCL (ug/L)	TREATED									
		WELL #8 (ug/L)			WELL #8 (ug/L)			WELL #10A (ug/L)			
		HIGH	LOW	AVG	HIGH	LOW	AVG	HIGH	LOW	AVG	
1,2,4-Trichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Hexachlorobutadinene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2,3-Trichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Trans-1,3-Dichloropropene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Cis-1,3-Dichloropropene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Benzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Toluene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Ethyl Benzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
m- Xylene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
p- Xylene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
o- Xylene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Styrene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Isopropylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
n-propylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,3,5-Trimethylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
tert-Butylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2,4-Trimethylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
sec-Butylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
p- Isopropyltoluene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
n-Butylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Methyl Tert. Butyl Ether (MTBE)	5.0	1.4	0.6	0.8	0.5	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorodifluoromethane	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Freon 113	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.

**NOTES:**

The elevated levels of Tetrachloroethene are removed by air stripping at our Water Mill Lane and Weybridge pumping facilities.

The volatile organic chemicals are tested quarterly at each well except when a well has not been used during the respective quarter. Volatile organic chemicals will be sampled at least once per year regardless if a well is used or not. Wells #2A, #6, #8, #9, #12, #13 and #14 raw water and treated water are tested for organic chemicals on a monthly basis when in service during the respective month.

N.D. = NON-DETECT

**WATER AUTHORITY OF GREAT NECK NORTH  
2013 SOURCE TESTING RESULTS**

Supplement to the 2013 Annual Drinking Water Quality Report as required by part #5 of the new York State Sanitary Code

VOLATILE HALOCARBONS (POC's)	MCL (ug/L)	WELL #11 (ug/L)			WELL #12 (ug/L)			TREATED WELL #12 (ug/L)		
		HIGH	LOW	AVG	HIGH	LOW	AVG	HIGH	LOW	AVG
		Dichlorodifluoromethane	5.0	1.5	0.6	1.2	N.D.	N.D.	N.D.	N.D.
Chlorodifluoromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chloromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Vinyl Chloride	2.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromomethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Trichlorofluoromethane	5.0	N.D.	N.D.	N.D.	1.7	N.D.	N.D.	N.D.	N.D.	N.D.
1,1-Dichloroethene	5.0	1.3	0.5	1.0	0.5	N.D.	N.D.	N.D.	N.D.	N.D.
Methylene Chloride	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
trans-1,2-Dichloroethene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1-Dichloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
2,2-Dichloropropane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
cis-1,2-Dichloroethene	5.0	N.D.	N.D.	N.D.	6.4	1.5	3.3	1.0	N.D.	N.D.
Chloroform	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromochloromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1,1-Trichloroethane	5.0	0.5	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1-Dichloropropene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Carbon Tetrachloride	5.0	0.6	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2-Dichloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Trichloroethene	5.0	N.D.	N.D.	N.D.	2.5	N.D.	1.3	N.D.	N.D.	N.D.
1,2-Dichloropropane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromodichloromethane	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Dibromomethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1,2-Trichloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Tetrachloroethene	5.0	1.5	0.5	0.9	1.3	N.D.	0.7	N.D.	N.D.	N.D.
1,3-Dichloropropane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorodibromomethane	50.0	0.7	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1,1,2-Tetrachloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromoform	50.0	0.6	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1,2,2-Tetrachloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2,3-Trichloropropane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
2-Chlorotoluene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
4-Chlorotoluene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,3 -Dichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,4 -Dichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2 -Dichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.

**NOTES:**

The elevated levels of cis-1,2-Dichloroethene and Trichloroethene are removed by Granulated Activated Carbon Filtration at our Community Drive pumping facilities. Air Strippers were installed in 2013 at Community Drive to treat for volatile organics.

The volatile organic chemicals are tested quarterly at each well except when a well has not been used during the respective quarter. Volatile organic chemicals will be sampled at least once per year regardless if a well is used or not. Wells #2A, #6, #8, #9, #12, #13 and #14 raw water and treated water are tested for organic chemicals on a monthly basis when in service during the respective month.

N.D. = NON-DETECT

**WATER AUTHORITY OF GREAT NECK NORTH  
2013 SOURCE TESTING RESULTS**

Supplement to the 2013 Annual Drinking Water Quality Report as required by part #5 of the new York State Sanitary Code

<b>VOLATILE AROMATICS (POC.2)</b>	<b>MCL (ug/L)</b>	<b>WELL #11 (ug/L)</b>			<b>WELL #12 (ug/L)</b>			<b>TREATED WELL #12 (ug/L)</b>		
		HIGH	LOW	AVG	HIGH	LOW	AVG	HIGH	LOW	AVG
1,2,4-Trichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Hexachlorobutadinene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2,3-Trichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Trans-1,3-Dichloropropene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Cis-1,3-Dichloropropene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Benzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Toluene	5.0	N.D.	N.D.	N.D.	0.6	N.D.	N.D.	N.D.	N.D.	N.D.
Ethyl Benzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
m- Xylene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
p- Xylene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
o- Xylene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Styrene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Isopropylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
n-propylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,3,5-Trimethylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
tert-Butylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2,4-Trimethylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
sec-Butylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
p- Isopropyltoluene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
n-Butylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Methyl Tert. Butyl Ether (MTBE)	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorodifluoromethane	50.0	N.D.	N.D.	N.D.	1.5	N.D.	N.D.	N.D.	N.D.	N.D.
Freon 113	50.0	N.D.	N.D.	N.D.	1.3	N.D.	N.D.	N.D.	N.D.	N.D.

**NOTES:**

The elevated levels of cis-1,2-Dichloroethene and Trichloroethene are removed by Granulated Activated Carbon Filtration at our Community Drive pumping facilities. Air Strippers were installed in 2013 at Community Drive to treat for volatile organics.

The volatile organic chemicals are tested quarterly at each well except when a well has not been used during the respective quarter. Volatile organic chemicals will be sampled at least once per year regardless if a well is used or not. Wells #2A, #6, #8, #9, #12, #13 and #14 raw water and treated water are tested for organic chemicals on a monthly basis when in service during the respective month.

N.D. = NON-DETECT

**WATER AUTHORITY OF GREAT NECK NORTH  
2013 SOURCE TESTING RESULTS**

Supplement to the 2013 Annual Drinking Water Quality Report as required by part #5 of the new York State Sanitary Code

VOLATILE HALOCARBONS (POC's)	MCL (ug/L)	WELL #13 (ug/L)			TREATED WELL #13 (ug/L)		
		HIGH	LOW	AVG	HIGH	LOW	AVG
Dichlorodifluoromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorodifluoromethane	5.0	1.0	N.D.	N.D.	N.D.	N.D.	N.D.
Chloromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Vinyl Chloride	2.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromomethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Trichlorofluoromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1-Dichloroethene	5.0	0.6	N.D.	N.D.	N.D.	N.D.	N.D.
Methylene Chloride	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
trans-1,2-Dichloroethene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1-Dichloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
2,2-Dichloropropane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
cis-1,2-Dichloroethene	5.0	1.7	N.D.	N.D.	N.D.	N.D.	N.D.
Chloroform	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromochloromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1,1-Trichloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1-Dichloropropene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Carbon Tetrachloride	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2-Dichloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Trichloroethene	5.0	0.8	N.D.	N.D.	N.D.	N.D.	N.D.
1,2-Dichloropropane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromodichloromethane	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Dibromomethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1,2-Trichloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Tetrachloroethene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,3-Dichloropropane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorodibromomethane	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1,1,2-Tetrachloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromoform	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1,2,2-Tetrachloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2,3-Trichloropropane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
2-Chlorotoluene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
4-Chlorotoluene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,3 -Dichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,4 -Dichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2 -Dichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.

**NOTES:**

The elevated levels of cis-1,2-Dichloroethene and Trichloroethene are removed by Granulated Activated Carbon Filtration at our Community Drive pumping facilities. Air Strippers were installed in 2013 at Community Drive to treat for volatile organics.

The volatile organic chemicals are tested quarterly at each well except when a well has not been used during the respective quarter. Volatile organic chemicals will be sampled at least once per year regardless if a well is used or not. Wells #2A, #6, #8, #9, #12, #13 and #14 raw water and treated water are tested for organic chemicals on a monthly basis when in service during the respective month.

N.D. = NON-DETECT

**WATER AUTHORITY OF GREAT NECK NORTH  
2013 SOURCE TESTING RESULTS**

Supplement to the 2013 Annual Drinking Water Quality Report as required by part #5 of the new York State Sanitary Code

<b>VOLATILE AROMATICS (POC.2)</b>	<b>MCL (ug/L)</b>	<b>WELL #13 (ug/L)</b>			<b>TREATED WELL #13 (ug/L)</b>		
		HIGH	LOW	AVG	HIGH	LOW	AVG
1,2,4-Trichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Hexachlorobutadinene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2,3-Trichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Trans-1,3-Dichloropropene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Cis-1,3-Dichloropropene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Benzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Toluene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Ethyl Benzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
m- Xylene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
p- Xylene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
o- Xylene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Styrene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Isopropylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
n-propylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,3,5-Trimethylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
tert-Butylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2,4-Trimethylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
sec-Butylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
p- Isopropyltoluene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
n-Butylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Methyl Tert. Butyl Ether (MTBE)	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorodifluoromethane	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Freon 113	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.

**NOTES:**

The elevated levels of cis-1,2-Dichloroethene and Trichloroethene are removed by Granulated Activated Carbon Filtration at our Community Drive pumping facilities. Air Strippers were installed in 2013 at Community Drive to treat for volatile organics.

The volatile organic chemicals are tested quarterly at each well except when a well has not been used during the respective quarter. Volatile organic chemicals will be sampled at least once per year regardless if a well is used or not. Wells #2A, #6, #8, #9, #12, #13 and #14 raw water and treated water are tested for organic chemicals on a monthly basis when in service during the respective month.

N.D. = NON-DETECT

**WATER AUTHORITY OF GREAT NECK NORTH  
2013 SOURCE TESTING RESULTS**

Supplement to the 2013 Annual Drinking Water Quality Report as required by part #5 of the new York State Sanitary Code

<b>VOLATILE HALOCARBONS (POC's)</b>	<b>MCL (ug/L)</b>	<b>WELL #14 (ug/L)</b>			<b>AIR STRIPPER - A (ug/L)</b>			<b>AIR STRIPPER - B (ug/L)</b>		
		HIGH	LOW	AVG	HIGH	LOW	AVG	HIGH	LOW	AVG
Dichlorodifluoromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorodifluoromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chloromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Vinyl Chloride	2.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromomethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Trichlorofluoromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1-Dichloroethene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Methylene Chloride	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
trans-1,2-Dichloroethene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1-Dichloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
2,2-Dichloropropane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
cis-1,2-Dichloroethene	5.0	3.0	N.D.	1.5	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chloroform	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromochloromethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1,1-Trichloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1-Dichloropropene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Carbon Tetrachloride	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2-Dichloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Trichloroethene	5.0	1.1	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2-Dichloropropane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromodichloromethane	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Dibromomethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1,2-Trichloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Tetrachloroethene	5.0	0.9	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,3-Dichloropropane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorodibromomethane	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,1,1,2-Tetrachloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromoform	50.0	N.D.	N.D.	N.D.	0.7	N.D.	N.D.	0.8	N.D.	N.D.
1,1,2,2-Tetrachloroethane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2,3-Trichloropropane	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Bromobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
2-Chlorotoluene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
4-Chlorotoluene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,3 -Dichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,4 -Dichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2 -Dichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.

**NOTES:**

The elevated levels of cis-1,2-Dichloroethene and Trichloroethene are removed by Granulated Activated Carbon Filtration at our Community Drive pumping facilities. Air Strippers were installed in 2013 at Community Drive to treat for volatile organics. The volatile organic chemicals are tested quarterly at each well except when a well has not been used during the respective quarter. Volatile organic chemicals will be sampled at least once per year regardless if a well is used or not. Wells #2A, #6, #8, #9, #12, #13 and #14 raw water and treated water are tested for organic chemicals on a monthly basis when in service during the respective month.

N.D. = NON-DETECT

**WATER AUTHORITY OF GREAT NECK NORTH  
2013 SOURCE TESTING RESULTS**

Supplement to the 2013 Annual Drinking Water Quality Report as required by part #5 of the new York State Sanitary Code

VOLATILE AROMATICS (POC.2)	MCL (ug/L)	WELL #14 (ug/L)			AIR STRIPPER A (ug/L)			AIR STRIPPER B (ug/L)		
		HIGH	LOW	AVG	HIGH	LOW	AVG	HIGH	LOW	AVG
1,2,4-Trichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Hexachlorobutadiene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2,3-Trichlorobenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Trans-1,3-Dichloropropene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Cis-1,3-Dichloropropene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Benzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Toluene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Ethyl Benzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
m- Xylene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
p- Xylene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
o- Xylene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Styrene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Isopropylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
n-propylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,3,5-Trimethylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
tert-Butylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
1,2,4-Trimethylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
sec-Butylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
p- Isopropyltoluene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
n-Butylbenzene	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Methyl Tert. Butyl Ether (MTBE)	5.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Chlorodifluoromethane	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Freon 113	50.0	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.

**NOTES:**

The elevated levels of cis-1,2-Dichloroethene and Trichloroethene are removed by Granulated Activated Carbon Filtration at our Community Drive pumping facilities. Air Strippers were installed in 2013 at Community Drive to treat for volatile organics.

The volatile organic chemicals are tested quarterly at each well except when a well has not been used during the respective quarter. Volatile organic chemicals will be sampled at least once per year regardless if a well is used or not. Wells #2A, #6, #8, #9, #12, #13 and #14 raw water and treated water are tested for organic chemicals on a monthly basis when in service during the respective month.

N.D. = NON-DETECT



**WATER AUTHORITY OF GREAT NECK NORTH  
2013 SOURCE TESTING RESULTS**

*Supplement to the 2013 Annual Drinking Water Quality Report as required by part #5 of the new York State Sanitary Code*

<b>CHLORIDES</b>	<b>HIGH</b>	<b>LOW</b>	<b>AVG</b>
WELL # 2A	43	31	37
WELL # 5	125	94	108
WELL # 6	33	30	31
WELL # 7	30	12	26
WELL # 8	65	54	58
WELL # 9	68	56	61
WELL #10A	24	18	21
WELL # 11	10	6	7
WELL # 12	33	12	24
WELL # 13	53	34	46
WELL # 14	57	6	31